

Declaration of Conformity

In Accordance with ANSI/ISEA 125-2014



Alexander Andrew, Inc. 1306 S. Alameda St Compton, CA 90221

Declaration # A0714009

Declaration Date 7.23.14

Tested Item # **7460A** **Parapet Anchor**

Additional Items Conforming Under this Declaration:

Alexander Andrew, Inc. declares that the product(s) listed above is in conformity with the requirements of the following performance standard(s):

OSHA 1926.502

Conformity Assessment Method in accordance with ANSI/ISEA 125-2014

Level 1

Level 2

Level 3

Level 1: FallTech Lab
Outside the Scope of
ISO/IEC Standard 17025:2005

Level 2: FallTech Lab
Within the Scope of
ISO/IEC Standard 17025:2005

Level 3: Independent 3rd Party Lab
accredited to
ISO/IEC Standard 17025:2005

Supporting Documentation **PC-0209**

Authorized Signature

Name Dustin Hawkins

Title VP Business Development

Date 2.9.15

FallTech Test Report

Test Report Number	PC-0209	Date	7/23/2014	Rev	B	Rev Date	11/12/2014
Report Prepared For	FallTech						
Initiated By	Dan Redden	Test Specification	OSHA 1926.502 1926.502(d)(15)				
Base Part #	7460A	Description	Parapet Anchor				
Proposed Part #	N/A	Built By Whom	Production	BOM	No		
Test Request #	PC-0209	Date Received		Date Complete	5/2/2014		
Test Operator	Dan Redden	Test Operator	N/A				

Material/Sample Identification

Sample ID	Description
PD74608	Parapet Anchor (Vertical Direction)
7460A-2	Parapet Anchor (Horizontal Direction)

Test Summary

Test Specification	Test Criteria		Test Result	Pass/Fail
OSHA 1926.502 1926.502(d)(15)	Vertical Static Strength	5,000 Lbf \geq 1 Minute	5,983 Lbf	Pass
OSHA 1926.502 1926.502(d)(15)	Horizontal Static Strength	5,000 Lbf \geq 1 Minute	5,274 Lbf	Pass

Conclusion

FallTech P/N 7460A Parapet Anchor meets the requirements of OSHA 1926.502.

Report Signatories and Approval

Lab Quality Manager Soung Liew		Date	7/25/2014
-----------------------------------	---	------	-----------

Witnessed by	Not Applicable	Date	Not Applicable
--------------	----------------	------	----------------

Rev A	Change P/N from 860 ZNC to 7460A
Rev B	Created Digital Copy

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to the joint ISO-ILAC-IAF Communiqué dated January 2009).